

Development of a power station unit in a distributed hybrid acquisition system of seismic and electrical methods based on NB-IoT

Feng Guo¹, Qisheng Zhang¹, Shenghui Liu¹

¹ School of Geophysics and Information Technology, China University of Geosciences Beijing, Beijing, 100083, China

Correspondence to: Qisheng Zhang (zqs@cugb.edu.cn)

Abstract. In this paper, we propose a new type of power station unit with wireless data transmission capability. This work breaks the limitation that conventional equipment is unable to upload data directly to central unit. Based on that, a novel distributed geophysical data acquisition architecture is also proposed, enhancing the work efficiency by simplify the system structure while maintaining core features. Designs that realize key functions including isolated high-power output, power management, wireless data transmission as well as high-precision clock synchronization etc. are introduced in this article.

The prototype was packaged then, and a series of evaluation experiments were implemented to verify the key parameters of the instrument. Experiment results proved that the overall design of the instrument is feasible, and the key parameters outperforms the industry leading instrument LAUL-428. Due to the wireless networking strategy, the proposed instrument further realizes remote control and real-time data playback through the host computer software, making it suitable for joint geophysical exploration as well as microseismic monitoring. As for system level, it could be customized by connecting different kinds of conventional acquisition stations for many kinds of prospecting targets.

删除了: Designs that realize functions including isolated high-power output, power management and monitoring, high-speed data transmission as well as high-precision clock synchronization etc. are

删除了: In a sense, a new birth was also given to the conventional seismic and electrical acquisition stations.⁴⁷

1 Introduction

The ambiguity problem of a single geophysical exploration method has always been a tricky problem in geophysical prospecting (Guo et al., 2020). Multi-method joint exploration has then become popular since it remains the advantages of different geophysical methods while reducing ambiguity problems. Among them, the joint exploration of seismic and electrical methods has become the research direction of many scholars (Garofalo et al., 2015; Wagner et al., 2019). However, the development of corresponding instrument is still at the very beginning.

Taking seismic exploration instruments as an example, the current seismometers can be divided into wired telemetry and wireless telemetry seismometers according to the communication method (Zhang et al., 2014). In the 1970s, SERCEL had already launched the SN338 digital seismograph and corresponding single-channel acquisition station (Qiao et al., 2019), then they launched SN388, 408UL, 428XL, 508XT and other products successively. At present, the most advanced seismic acquisition system in the world is 508XT system, which has a real-time acquisition capability. The 428XL seismic acquisition system, however, is the most widely used system in the entire geophysical prospecting industry at present, who has the most representative system arrangement structure. The system shown in Figure 1(a) is mainly composed of a central

control unit (e-428), a line control interface (LCI-428), a transverse station (LAUX-428), a line power (LAUL-428) and a collection chain (Link). The collection chain consists of several acquisition stations (FDU-428) or digital sensors (DSU-428) that connected by cables (Sercel, 2006). LCI is the interface between the arrangement and e-428 client, which plays the role of high-speed Ethernet routing. The main function of LAUX is to collect and package data from the arrangement and send them to another LAUX unit or LCI. LAUL is connected directly with Link through the cable, then power is supplied to the acquisition nodes on the Link and the data are relayed as well (Sercel, 2007). The 508 system upgrade this structure further by combing LAUL and LCI, and replace them with CX-508 (Sercel, 2023). This, however, didn't combine wireless communication function (Duan, 2019). Besides, the Inova G3i NXT (Inova, 2022), I/O Scorpion (Gan, 2013), and Seismic Instruments (2023) shared the same system structure with 428XL, and a transverse station or line control interface is necessary. Other geophysical exploration system, such as that for Multi-channel Transient Electromagnetic Method (MTEM), share the similar structure in cabled manner with above mentioned system, and wireless quality check function added (Dong, 2015).

In despite of the burst of nodal seismograph e.g., Hawk, SmartSolo, WTU-508 (Lv et al., 2022) and others developed by Tian (2020) etc., the wired seismograph system is suitable for certain exploration situations (Ellis, 2014). As is found by Lansley (2012), the best way of exploration system structure in the near future should be the combination of wired and wireless system, which could also be proved by the upgrade from 428XL system to the 508XT system developed by industry leading company. In fact, as analyzed by Dean et al. (2013), for dense exploration with receiver interval less than 40m, the cabled system weighs less than nodal system, and specifically, when receiver interval is 10 m, the cabled system weighs only 24% of the nodal system.

Combining the seismic and electrical acquisition stations developed by our team, a new type of power station unit (PSU) is proposed, thus a geophysical instrument networking method is also proposed in this article. The point is to retain the original functions of the LAUL and integrate the upward communication and human-computer interaction capabilities of the LCI by wireless communication. Therefore a 120-channel acquisition arrangement is developed based on a single PSU. This arrangement can be further expanded through wireless networking, which could be very convenient for joint geophysical exploration including seismic exploration and high-density electrical method exploration on complex terrain (R. G. Heath, 2008). Compared with traditional wired systems, the proposed structure can reduce a considerable number of equipments to form an efficient work and data transmission flow.

2 Overall design

The proposed PSU based system is shown in Figure 1(b). A single PSU could connect and supply power to a series of acquisition stations (AS) via the cable by two connectors, one on each side. The PSU serves as the main control unit by sending the control commands to the AS in a relay manner. After signal acquisition, the data are relayed on the line to upload from the AS at the end of the arrangement. The intermediate AS add their own data to the data frame and then continue to

删除了: ts

删除了: ts

删除了: distributed

删除了: field

删除了: ACs

删除了: ACs

删除了: AC

删除了: ACs

upload forward until the PSU. Meanwhile, the PSU also performs as the human-computer interaction interface. Unlike the 428XL system, no cables or additional LCI are required between PSU and the central control unit. Instead, Wi-Fi and Narrow Band Internet of Things (NB-IoT) are implemented as remote data transmission techniques, thus expanding the system scale to a larger extent through wireless networking. This layout is flexible and suitable for complex terrains in the wild or urban underground space detection.

2.1 Design targets

The design target is to integrate the functions that belonged to LCI and LAUX originally, into the PSU. Therefore, the aims are:

- 1) Solving the problem that output voltage level of external battery decrease when discharging to provide stable and high-quality power to the acquisition station arrangement. And monitoring the power status at the same time.
- 2) Receiving control commands from the host computer and configuring the acquisition station arrangement accordingly, while uploading received data to the host computer.
- 3) Buffering and preprocessing the uninterrupted data stream uploaded by the acquisition stations.
- 4) Providing a high-precision clock source for connected **AS** and add absolute time information to the data.

删除了: ACs

3 Design of hardware circuits

The PSU adopts a modular hardware design, consisting of interface board, boost board (2 pieces), power board, ARM® main control board (ARM® board), FPGA (Field Programmable Gate Array) board, clock board, and built-in back-up lithium battery. The hardware structure is shown in Figure 2.

All circuit boards are fixed in the enclosure shown in Figure 3. The interface board is installed on the connector side, and the other circuit boards are fixed together by metal screws on the bottom of the case. Between circuit boards, board-to-board connectors or flat cables are used. In this way, the spacing and quantity of the boards are adjustable, therefore the circuit boards could be replaced easily for fixing and upgrading.

3.1 Design of interface board

The interface board mainly realizes the transfer from each interface on the instrument enclosure to the internal circuits, whose shape and position therefore correspond to each interface on the enclosure.

Another main function of the interface board is to select a reliable power supply from external battery or the built-in battery. In this case, the power path controller LTC4416 is introduced to control 2 sets of external P-channel Metal Oxide Semiconductor Field Effect Transistors (MOSFET) to realize a nearly ideal diode function for the power switching circuit. It also expands the function of power sequencing while realizing power supply combination and reverse connection protection.

When valid external power supply is connected, the power source would be selected according to the preset voltage

threshold, thereby saving the back-up battery. If voltage level of external source drops lower than that threshold, back-up battery would be switched to automatically to avoid the power interruption due to external power failure during field exploration.

110 **3.2 Design of boost board**

The function of the boost board is to output and monitor 48 V power for acquisition stations which is boosted from the unstable 12 V input from external battery. To load more stations and provide flexibility while set-up, we designed a dual output link strategy, which means two boost boards are in need for each power link.

3.2.1 Boost circuit

115 The voltage boost is realized by VI-204-CX type DC-DC (direct current-direct current) module, whose input voltage range is 10-20 V, and the output voltage is 48 V. In this case, our theoretical maximum output power is 75 W for single boosted output source, and the conversion efficiency can reach up to 90%. The power output of the PSU is controllable; therefore, the boost output can be turned off to reduce power consumption during parameter configuration when power supply to the acquisition stations is not in need.

120 **3.2.2 Output power monitoring circuit**

In the PSU, the output power source is monitored by measuring current and voltage, and simultaneously calculate the power value relying on LTC2945 utilizing its integrated multiplier who performs digital multiplication directly on the measured current and input voltage data to generate a 24-bit power value. Those acquired data are continuously sampled and stored in the internal register of LTC2945 and meanwhile the maximum and minimum values are updated (Linear Technology, 2012).

125 Both maximum and minimum thresholds for voltage, current and power can be configured. When physical value beyond this threshold range is detected, a fault signal will be output through the ALERT pin. Microcontroller Unit (MCU on power board) configures this signal as an external interrupt source, and will give rapid response to this interrupt, which is shutting down the 48V output, in case abnormal situations happen.

3.3 Design of power board

130 The main function of the power board is to monitor the input power and convert it to 5 V, 3.3 V, 1.1 V power for other internal circuit boards. In addition, the control of the boost board, switches and LED indicators on the instrument panel are also realized by the power board.

3.3.1 Power board control circuit

The main tasks of power board control circuit are listed as below, therefore an independent microcontroller is needed to achieve those complicated functions. Here, the MSP430G2553 is selected.

Table 1. Power board control MCU task and hardware resources in need

MCU hardware resources	Task
General Purpose Input/Output	Signal control
External interrupt	Fault signals respond from the power monitoring circuit (boost board)
Timer interrupt	Software timing and pulse width modulation output
Comparator	External or internal power supply determination
I2C	Power information reading
UART	ARM® board communication

3.3.2 DC-DC conversion circuit

The DC-DC conversion circuit is used to convert the unstable input voltage, usually 9-16 V using lead batteries, to a stable 5 V/3.3 V/1.1 V voltage for specific internal power requirements. Considering the large conversion voltage drop, the PTH08080W switching mode power supply module is used since it has a conversion efficiency of 80%-93% in the entire load range, which is 4.5-18 V for input, and 0.9-5.5 V for adjustable output.

3.4 Design of ARM® main control board

The ARM® board integrates the core board of the AM4379 (Texas Instrument, 2013) processor and various communication interfaces. The structure of main control board is shown in Figure 4.

The ARM® board communicates with FPGA using General Purpose Memory Controller (GPMC) interface and interacts with the power board through the UART serial port. Acquisition data is stored by micro-SD card. Remote monitoring and control are carried out through NB-IoT. In addition, 2.4 GHz and 5 GHz dual-band Wi-Fi module is introduced to realize wireless control and data transmission. For back-up data transmission and debugging interfaces, ethernet and RS232 serial ports are also reserved. In this case, an industrial-grade core board SOM-TL4379 based on TI AM4379 is used.

NB-IoT realizes remote data transmission between PSU and upper computer in low power consumption. The NB-IoT chip named M5310-A communication module supports LTE Cat-NB1/NB2 and has the characteristics of low power consumption (3 μ A @ PSM mode) and ultra-high operating temperature range. The network topology is shown in Figure 5. Data is

删除了: MCU on power board mainly include

移动了(插入) [1]

删除了: :

删除了: Based on that,

删除了: microcontroller was selected.

上移了 [1]: Based on that, MSP430G2553 microcontroller was selected.

160 transmitted from MCU through UART interface to the NB-IoT module, then uploaded to the OneNET cloud platform via the
NB-IoT base station (China mobile, 2018). Client then accesses the uploaded data from the OneNET cloud platform.
Wi-Fi, on the other hand, is introduced for high-speed wireless acquisition data uploading (to upper computer) and other
functions. In the proposed instrument, TiWi5 Wi-Fi module supporting 2.4 GHz and 5 GHz dual frequency bands is used
(Laired Connectivity, 2016). Comparing to 2.4 GHz, 5 GHz frequency band relieves network congestion, providing better
165 signal coverage and faster transmission speed.

3.5 Design of FPGA board

The FPGA board is used to process a huge number of digital signals and logic control (De La Piedra A. and Braeken A.
Touhafi, 2012). The main functions are as follows:

- 1) Communicate with the acquisition stations based on the improved LVDS interface to achieve the acquisition station
170 control and data uploading from acquisition stations to the PSU.
- 2) Receive control commands from the ARM[®] board and transmit the acquired data to the ARM[®] board using the GPMC
interface.
- 3) Control the clock board, and complete GPS signal analysis as well as Oven Controlled Crystal Oscillator (OCXO)
calibration.

175 LVDS communication is well supported by FPGA 5CEBA2F7 with integrated LVDS transceiver on-chip. OCT (On-Chip
Termination) can be used by LVDS receiver to achieve impedance matching, without external termination resistors.

The transmission signal on the line is a high-voltage signal based on Power on Ethernet (PoE) technology realizing power
supply and data transmission simultaneously. And this gives the explanation of the ARM[®] + FPGA dual core design. LVDS
data in Manchester encoding from cable are decoded by FPGA and transmitted to ARM[®] board then for further data
180 uploading, processing, or internal data storage.

3.5 Design of clock board

To improve the measurement accuracy of AS and achieve synchronization between PSUs, an accurate clock source is
required (Cao et al., 2010). The high-precision clock system design scheme is shown in Figure 6. FPGA uses 10
185 accumulative Pulse Per Second (PPS) signal generated by the GPS receiver as the time gate to measure the frequency of the
OCXO. Frequency deviation of the OCXO is then calculated and the corresponding calibration value is obtained. According
to the calibration value, the digital voltage control value is generated and sent to the Digital to Analog Converter (DAC).
After conversion, the analog voltage is output to the voltage control terminal of the OCXO to realize the calibration.
LEA-6T GPS module, whose timing accuracy reaches 15 ns, perform timing when only one satellite is visible is utilized in
190 this case (Ublox, 2017), to ensure the precision of PPS source.

删除了: ACs

删除了: 5

删除了: u

195 The OCXO on the other hand reduces the output frequency change of oscillator caused by temperature variation by stabilizing the internal temperature, but there is still cumulative error. As the working time increases, the clock error will gradually increase. Take the OCXO in this case as an example, whose output frequency is 12.288 MHz with frequency stability is $\pm 5 \times 10^{-8}$. If no calibration is implemented, the accumulated error after one day could be:

$$\begin{aligned}\Delta t &= \left(1 - \frac{f_s}{f_s \pm f_s \cdot k}\right) \times 3600s \times 24 \\ &= k \cdot \frac{1}{1 \pm k} \cdot 86400 \\ &= 5 \times 10^{-8} \times \frac{1}{1 \pm 5 \times 10^{-8}} \times 86400s \approx 4.32 \times 10^{-3}s = 4.32ms\end{aligned}\quad (1)$$

Here, f_s is the standard frequency of OCXO and k represents the frequency stability.

200 Assuming that the sampling interval is set to 1ms, there will be an error of 4 sampling points after a one-day acquisition. Therefore, the OCXO must be calibrated to improve the frequency accuracy.

The selected OCXO is voltage controlled, thus a voltage of 0-5 V is applied to the CONTROL pin to achieve precise adjustment of the output frequency and the pull range is $\pm 5 \times 10^{-7}$ s. The 12bit DAC7512 (Texas Instrument, 2012) is used to produce the control voltage, producing the frequency adjustment of 2.5×10^{-10} s per step. Since that, accurate frequency calibration could be achieved.

205

4 Design of software program

The ARM® board applications are developed based on the Linux platform. The main tasks are: 1) communicating with the power board to manage the PSU and the acquisition station arrangement; 2) accessing the micro SD card for file storage; 3) communicating with the FPGA board to control the acquisition stations and to receive acquired data from the acquisition stations; 4) accessing the Wi-Fi module to realize the wireless communication function; 5) communicating with the NB-IoT module to realize remote control and real-time quality monitoring; 6) debugging through serial port and network port.

210

Each part of the function is implemented by a separated thread to improve the response speed of the applications and ensure that the system would not be blocked by a single task. In addition, there is a main thread module running after system launch, which is mainly responsible for device initialization and starting other threads.

215 4.1 Power board programming

The power board mainly realizes the functions of power monitoring, fault response, boost board control, interface board control, etc. The program flow chart is shown in Figure 7.

After the MCU on the power board is powered on, modules including GPIO, timer, serial port, comparator, I2C interface, etc. will be initialized firstly. Then, the global interrupt is turned on, while the MCU enters the low-power-consumption mode and will not be awakened until interrupt is generated.

220

删除了: 6

The timer interrupt interval is set to examine the power source status. When timer interrupt request is generated, the MCU will read the data in the register of LTC2945. If the threshold value is not exceeded, the data will be uploaded directly to the ARM® board in specific format, and the MCU sleeps again to enter the low power consumption mode. If there is a certain
225 item of data that exceeds the threshold, further judgment will be executed to analyze the type of data that exceeds the threshold. When the battery voltage drops to a certain segment point, the status of the battery indicator will be switched. If the output voltage, current, or system power exceeds the normal operating range, an early warning signal will be issued to prompt the user to troubleshoot.

There are three interrupt sources for I/O interrupts, connecting to the "Alert" signals of three pieces of LTC2945 respectively.
230 If the fault comes from the boost board, the MCU will shut down the corresponding boost module firstly to ensure the safety of the acquisition line, then send a fault signal through the indicator light to remind the user and upload the fault data to the ARM® main control board. If the fault comes from the battery that input power, since the power switch cannot be turned off directly by software, the MCU can only issue a fault indication and upload fault data.

The serial port of the MCU is connected to the ARM® board, and the serial port interrupt is used to respond to the control
235 commands of the ARM® board. After receiving the serial port data, the MCU will parse out the command and determine whether it conflicts with the current state. If no conflict, the corresponding operation will be executed directly. However, on condition that a conflict exist, meaning that there is a communication problem between the power board and the ARM® main control board, the conflict will be reported to the ARM® board.

The power selection indication signal output by LTC4416 is connected to the comparator input port of MCU. When the
240 power supply is switched between the external power supply and the back-up battery, the comparator interrupt is triggered. Then the MCU will determine the current power source and report the status to the ARM® board.

4.2 ARM® application programming

As the main control unit of the PSU, the ARM® board needs to receive commands from host computer to complete tasks including power supply management, parameter setting as well as storing and uploading data. The amount of data to process
245 is huge and multiple tasks are executed concurrently. Therefore, an operating system must be equipped to manage system resources and schedule multiple applications uniformly, and to provide users with file systems and hardware access interfaces.

The ARM® board applications are developed based on the Linux platform, and details are given in Figure 8. The main tasks
250 are: 1) communicating with the power board to manage the PSU and the acquisition station arrangement; 2) accessing the micro SD card for file access; 3) communicating with the FPGA board to control the acquisition stations and to receive acquired data from the acquisition stations; 4) accessing the Wi-Fi module to realize the wireless communication function; 5) communicating with the NB-IoT module through the serial port to realize remote control and real-time quality monitoring; 6) debugging through serial port and network port.

删除了: 7

255 Each part of the function is implemented by a separated thread to improves the response speed of the application and ensures that the system would not be blocked by a task occupied too much time. In addition, there is a main thread module, running after the system is launched, is mainly responsible for device initialization and starting other threads.

4.3 Design of FPGA board program

4.3.1 Manchester encoding

260 The high-speed data transmission between PSU and [AS](#) is based on improved LVDS, and the PoE power supply as well as signal isolation are realized through the isolation transformer. But at the same time, the isolation transformer will also cut off the DC component of the signal. Therefore, only the AC component of the input signal will be observed at the receiver. When continuous binary 0 or 1 appears in the data, the voltage at receiving end will drop, causing signal jitter and bit errors. Therefore, the Manchester encoding technology is introduced to solve this problem. The positive edge represents data 0, and
265 the negative edge represents data 1 ([Lalitha V. and Kathiravan S., 2014](#); [Suchitra S., 2013](#)). However, since two data bits are used to represent one bit of information, the data transmission efficiency is reduced by half.

删除了: ACs

删除了: .

4.3.2 Design of clock board control program

The frequency measurement calibration program is implemented by FPGA using HDL (Hardware Description Language), which is mainly composed of delay reset module, clock calibration module and DAC control module. The program
270 workflow is illustrated as Figure 6. The delay reset module releases a reset signal 10 seconds after power-on to wait for the internal oven-controlled chamber of the OCXO reach the working temperature. The clock calibration module then measures the output frequency of the OCXO while calculating the calibration amount. The gate time used for measurement is the time interval of 11 consecutive PPS signals (10 s). Within the gate time, the output of OCXO is counted and compared with the theoretical value to generate a calibration value, which is output to the DAC control module. The DAC control module then
275 generates the control signal and writes it in a certain timing sequence to DAC7512. In this way, a single calibration is executed. When the difference between the counted value and the theoretical value decreases to a certain range, the calibration is completed.

删除了: 5

5 Performance

After the design and assembly of the instrument, a series of verification experiments were [implemented](#) to evaluate the major
280 performance of the instrument.

删除了: carried out

285 5.1 Output power experiment

Supplying power to the acquisition line on both sides is the key function of the power station unit, thus the load capability of the PSU is an important technical parameter. Firstly, a simulated load is used instead of AS to evaluate the maximum power output ability. The average measured output power of one side is:

$$P = 47.36V \times 1.39A \approx 65.83W \quad (2)$$

290 According to the results above, the total load capacity of the power station unit can reach 131.66 W.

We then implemented an output power evaluation experiment with AS to illustrate the output power variation with different AS quantities. Acquisition stations of one seismic and one electrical acquisition channel have been chosen as the load, and the interval between acquisition stations is 20 m in the experiment. All two power output port are used to decrease the power consumption on the cable. Output curve with AS quantity increasing is illustrated as Figure 9, which was fitted from 7 sets of discrete output power value points listed in the table at the upper left corner. This experiment proved that the proposed PSU could supply power to 120 AS.

5.2 Remote control experiment

To upload quality control information and realize the human-computer interaction, the communication experiment based on NB-IoT is carried out to achieve the data transmission from end to cloud. As is shown in Figure 9, the remote-control functions are including online device scanning, acquisition status control, battery status, GPS information, network signal strength, etc. In the evaluation experiment, PSU supplied power to 8 seismic-electrical hybrid acquisition stations simultaneously, and the acquisition stations are controlled to enter several working conditions through remote commands. Other indoor performance experiments have been implemented as well, and the result shows that the downstream data throughput is 8.86 kbps averaged and the package latency is 1183 ms based on LWM2M protocol. By remote controlling, long-term monitoring during joint prospecting of seismic and electrical methods can be carried out, and it has good application prospects in urban underground space detection and shallow surface-wave exploration. Using the NB-IoT network can avoid serious interference from the wireless network, providing better signal coverage and signal quality.

5.3 Comparison

After above-mentioned evaluation experiments, comparison between proposed PSU and the state-of-art LAUL-428 is listed in table 2. First, the proposed PSU owns an advantage in providing power supply to more acquisition stations (AS) simultaneously than LAUL-428. The test is carried under the condition of 20m interval between each AS with a 2ms sampling interval to match the test condition of LAUL-428 provided by their official manual (Sercel, 2007). Another technical advantage is that PSU has the ability of data communication which is not supported by LAUL-428.

315 **Table 2.** Comparison between PSU and LAUL-428

删除了: ACs

删除了: with various l

删除了: oad

删除了: , which has a total power consumption of 0.72 W

删除了: load

删除了: f

删除了: 8

删除了: .

删除了: shows

删除了: ACs

删除了: 9

	LAUL-428	PSU
Data transmission speed	8Mbps, 16Mbps	16Mbps (Manchester encoding)
Maxim acquisition stations	81 FDU ^s TM	120 AS
Function	Power supply: 50_V output	Power supply: 48_V output
Operating power	10.5-15_V DC input 2 battery connectors	4.5-18_V DC input Internal backup battery
Wireless data upload	—	NB-IoT & Wi-Fi (2.23 MB/s @ 1 km)
Memory	30_MB local buffer	32_GB microSD card
Weight	2.40_kg	2.27_kg
Operating Temperature	-40_°C to +70_°C	-40_°C to +70_°C
Durability & Resistance	15m deep in water	Water repellent and dust resistant

删除了: V

6 Conclusion

In this article, a new power station unit is designed for joint geophysical exploration. Combining with hybrid acquisition stations and upper computer software, a novel distributed wireless seismic and electrical method hybrid acquisition system becomes realistic as well.

Compared with the traditional wired seismograph system, the structure of PSU system is much simpler, and the acquisition data could be uploaded directly from PSU to the central unit through wireless local area network.

The proposal of PSU system has several advantages over nodal instruments as well (Qiao et al., 2019). Firstly, power supply through the proposed PSU could be more stable and sustainable and is more convenient for power management. Secondly, unlike the nodal instrument who uploads data individually, the PSU packs data from 120 acquisition stations and upload them to the central unit through WLAN in real-time, therefore alleviate the channel congestion problem, providing a long-term stable work support and a larger channel quantity. Owing to the NB-IoT technology, who gives the functions of remote control and quality check, networking with other IoT based instruments for multi-parameter geophysical exploration could be expected.

The PSU simplifies system structure of seismic and electrical prospecting and reduces the overall cost, forming a wired and wireless hybrid distributed acquisition system. A multitude of geophysical exploration methods, namely reflection, refraction, surface wave exploration, as well as high-density electrical exploration could be carried out. In conclusion, the proposed PSU is a crucial part of a new distributed hybrid acquisition system architecture of seismic and electrical prospecting.

345 **Acknowledgment**

This work is supported by the Natural Science Foundation of China (No. 41574131 and No. 41204135), the PetroChina Innovation Foundation (No. 2019D-5007-0302).

References


- 350 Guo, F., Zhang, Q., Zhang, Q., Li, W., Luo, Y., Niu, Y., and Qiao, S.: Development of a new centralized data acquisition system for seismic exploration, *Geosci. Instrum. Method. Data Syst.*, 9, 255–266, <https://doi.org/10.5194/gi-9-255-2020>, 2020.
- Garofalo F, Sauvin G, Socco L V, et al. Joint inversion of seismic and electric data applied to 2D mediaseismic and electric data joint inversion. *Geophysics*, 80, 4, 93-104, 2015.
- 355 Wagner F M, Mollaret C, Günther T, et al.: Quantitative imaging of water, ice and air in permafrost systems through petrophysical joint inversion of seismic refraction and electrical resistivity data, *Geophysical Journal International*, 219, 3, 1866-1875, <https://doi.org/10.1093/gji/ggz402>, 2019.
- Zhang S. S., Zhang L. H., Lin J. et al.: Summary of development of telemetry seismometers, *Prog. in Geophys.*, 29, 3, 1463-1471, <https://doi.org/10.6038/pg20140365>, 2014. [in Chinese]
- 360 Qiao S.Q., Zhang Q.S., Zhang Q. M.: Mine fracturing monitoring analysis based on high-precision distributed wireless microseismic acquisition station, *IEEE Access*, 7, 1, 147215-147223, <https://doi.org/10.1109/ACCESS.2019.2946443>, 2019.
- Sercel Inc.: 428XL reference training guide, Carquefou Cedex France: Sercel Inc, 2006.
- Sercel Inc.: 428XL user manual, Carquefou Cedex France: Sercel Inc, 2007.
- Sercel Inc. 508XT Brochure: <https://www.sercel.com/products/Pages/508-XT.aspx>, last access: 31st Jan 2023.
- 365 Duan C. P., Zhai L. X., Wu S. P. et al.: Function description and application of CX-508 in seismic data acquisition system, *Equip. for Geophys. Prosp*, 29, 2. 2019. [in Chinese]
- Inova G3i NXT: https://d1cvtcw7p7ix4u.cloudfront.net/images2/downloads/G3i-NXT-Datasheet_yellowlogo.pdf?mtm_e=20220404153431&focal=none, 2022.
- Gan Z. Q.: Discussion on performance analysis of several mainstream seismic exploration instruments, *Petroleum Instruments*, 27, 1, 21-24, 2013. [in Chinese]
- 370 Seismic Instruments: <http://www.seismicinstruments.com/products/bbu.html>, last access: 30th Jan 2023.
- Dong Q. Y.: Implementation of battery management unit in MTEM system, M.S. thesis, University of Science and Technology of China, China, 71pp., 2015.
- Ellis R.: Current cabled and cable-free seismic acquisition systems each have their own advantages and disadvantages—is it possible to combine the two?, *First Break*, 32,1, 91-96, <https://doi.org/10.3997/1365-2397.32.1.72599>, 2014.

- Lv, S., Lin, J., Yang, H., Tian, R., Wang, L., Bin, K., Tong, X., & Li, A.: Development and prospect of the nodal cable-free seismograph: a review. *Measurement Science and Technology*, 33, 10, <https://doi.org/10.1088/1361-6501/ac72fa>, 2022.
- Tian R. Y., Wang L. X., Jiang Y. J., Lin J., Zhang L. H. and Zhou X. H.: Wireless Multi-Hop Energy-Efficient System for High-Density Seismic Array, *IEEE Access*, 8, 26054-26066, <https://doi.org/10.1109/ACCESS.2020.2971083>, 2020.
- 380 Lansley, M.: Cabled versus cable-less acquisition: making the best of both worlds in difficult operational environments. *First Break*, 30, 97–102, <https://doi.org/0.3997/1365-2397.30.1.56181>, 2012.
- Dean, T., O'Connell, K., & Quigley, J.: A review of nodal land seismic acquisition systems, 164, 34–39. <https://doi.org/10.1071/pvv2013n164p34>, 2013.
- R. G. Heath: Trends in land seismic instrumentation. *The Leading Edge*, 27 (7): 872–877. <https://doi.org/10.1190/1.2954026>.
- 385 2008.
- Linear Technology LTC2945 - Wide range I2C power monitor: <https://www.analog.com/media/en/technical-documentation/data-sheets/2945fb.pdf>, 2012.
- Texas Instrument MSP430G2X53 mixed signal microcontroller: https://www.ti.com/lit/ds/symlink/msp430g2553.pdf?ts=1599736963866&ref_url=https%253A%252F%252Fwww.ti.com%252Fsearch%252Fdocs%252Funiversalsearch.tsp%253FsearchTerm%253Dmsp430g2553, 2013.
- 390 China Mobile M5310-A NB-IoT communication module: http://iot.10086.cn/Uploads/file/product/20181109/M5310-A_20181109103230_35807.pdf, 2018.
- Laired Connectivity TiWi5 dual-mode Wi-Fi module with Bluetooth: <https://www.lairdconnect.com/wireless-modules/wifi-modules-bluetooth/tiwi5-dual-mode-wifi-module-bluetooth>, 2016.
- 395 De La Piedra A., Braeken A., Touhafi A: Sensor systems based on FPGAs and their applications: A survey, *Sensors*, 12, 9, 12235-12264, <https://doi.org/10.3390/s120912235>, 2012.
- Cao P. , Song K. , Yang J. , et al: Design of a large remote seismic exploration data acquisition system, with the architecture of a distributed storage area network, *Journal of Geophysics and Engineering*, 8, 1, 27-34, <https://doi.org/10.1088/1742-2132/8/1/005>, 2010.
- 400 U-blox LEA-6 u-blox 6 GPS modules data sheet: https://www.u-blox.com/sites/default/files/products/documents/LEA-6_DataSheet_%28UBX-14044797%29.pdf, 2017.
- Texas Instrument Low-power, rail-to-rail output, 12-bit serial input digital-to-analog converter: https://www.ti.com/lit/ds/symlink/dac7512.pdf?ts=1599707710212&ref_url=https%253A%252F%252Fwww.ti.com%252Fsearch%252Fdocs%252Funiversalsearch.tsp%253FsearchTerm%252DDAC7512, 2012.
- 405 [Lalitha, V., Kathiravan, S., A review of manchester, miller, and fm0 encoding techniques, *SmartCR*, 4\(6\), 481-490, 2014.](#)
- [Suchitra S., Vhdl Implementation of Manchester Encoder and Decoder, *International Journal of Electrical, Electronics and Data Communication*, 1 \(2\) , 2320-2084, 2013.](#)

删除了: .

删除了:

设置了格式: 字体: 非倾斜



410

Figure 1: (a) structure diagram of 428XL system; (b) system structure of PSU (AS: Acquisition Station)





Figure 2: Hardware structure diagram of PSU.



415 Figure 3: Three-dimensional structure diagram of PSU's external case.





Figure 4: Structure diagram of ARM® main control board



420 **Figure 5:** NB-LoT based networking topology





Figure 6: High-precision clock system design scheme



425 **Figure 7:** Power board software program flow chart

带格式的: 正文, 居中

删除了: 5

删除了: 6

删除了: .

430




Figure 8: ARM® main control board application

删除了: 7

删除了: .




Figure 9: Output power evaluation test

删除了: 8

435

Device	Loads	Battery percentage	Operational state	GPS coordinates	Signal intensity/dBm	Dropped packs
CUGB-SPS1	8	73%	Acquiring	E:116.351890, N: 39.989735	-85	0

440 Figure 10-7 NB-IoT remote control interface

